

# Emission Test Certificate

Monday 21<sup>st</sup> August 2023

**Supplier** CSR Building Products Ltd (Trinity 3, Level 5, 39 Delhi Road, North Ryde, NSW, 2113, Australia)

**Product Name** Gyprock ECO8™ Complete

**Date Tested** April 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

## Emission Data (24 hours)

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b>	<b>Gyprock ECO8™ Complete</b>
Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.043 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.008 mg/m <sup>2</sup> /hr
<p><i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by CSR Building Products and these include <b>Gyprock Fyrchek™</b>, <b>Gyprock Fyrchek™ MR</b>, <b>Gyprock Aquachek™</b>, <b>Gyprock HD</b>, and <b>Gyprock Soundchek™</b>.</i></p>	



Dr. Vyt Garnys  
 Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Travis Hale  
 BSc (Biotechnology)  
 Senior Consultant



Dr Tuan Duong  
 Ph.D., B.Eng. (Chemical)  
 Senior Consultant

Issued Date: 13/06/2023

Expired Date: 14/06/2028

P23030017\_Ver2