

Emission Test Certificate

Wednesday 14th June 2023

| Supplier | CSR Building Products Ltd (Triniti 3, Level 5, 39 Delhi Road, North Ryde, NSW, 2113, | |
|--------------|--|--|
| | Australia) | |
| Product Name | Gyprock Gyptone | |
| Date Tested | April 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231) | |
| Test Method | ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber | |
| | Determinations of Organic Emissions from Indoor Material/Products". | |

Emission Data (24 hours)

| Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B | Gyprock Gyptone |
|--|---|
| Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr | Total Volatile Organic Compound Emission Rate: 0.017 mg/m ² /hr |
| Formaldehyde Emission Rate Limit: ≤0.100 mg/m²/hr | Formaldehyde Emission Rate: < 0.005 mg/m²/hr |

Dr. Vyt Garnys Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ ACA, AIRAH, FMA Managing Director and Principal Consultant

Travis Hale BSc (Biotechnology) Senior Consultant

MADOUR

Dr Tuan Duong Ph.D., B.Eng. (Chemical) Senior Consultant

Issued Date: 14/06/2023

Expired Date: 14/06/2028

P23030017