

VOC Content Test Certificate

Tuesday 28th August 2025

Supplier: CSR Limited (376 Victoria St, WETHERILL PARK, NSW, 2164, AUSTRALIA).

Product Name: Gyprock All-Coat MAX™

Date Tested: 17th October 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Gyprock All-Coat MAX™
General Purpose Adhesives and Sealants Limit: 50 grams per litre	1 gram per litre as VOC content per material
<i>We hereby certify Gyprock All-Coat MAX™ is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant